

THERMAL TRANSMITTANCE CALCULATION


Calculation num.: 173.1/12

PRODUCT STANDARD: EN 14351-1 + A1

CALCULATION STANDARD: EN 1077-2:2012

SOFTWARE: WinIso 2D

VALIDITY: The data and results refer solely to the described specimen or to the specimen of bigger dimension but with the same frame and glazing details.

WINDOW TYPE Nature E92**PRODUCT** Single tilt and turn window

Frame material	Wood – spruce/fir
Thermal transmittance of frame	$U_f = 0,91 \text{ W/m}^2\text{K}$, $b = 115\text{mm}$ $U_{f,\text{bot}} = 0,97 \text{ W/m}^2\text{K}$, $b = 124\text{mm}$
Thermal transmittance of glazing	$U_g = 0,7 \text{ W/m}^2\text{K}$ 8/12Ar/8/12Ar/8
Linear thermal transmittance of frame/glazing junction	$\Psi = 0,051 \text{ W/mK}$
Window dimension (w x h)	1230 mm x 1480 mm

 $U_w = 0,87 \text{ W/m}^2\text{K}$